



Todd Harms
Fire Chief

Sacramento Metropolitan Fire District

Community Risk Reduction Division

www.metrofire.ca.gov

10545 Armstrong Ave., Suite 310 • Mather, CA 95655 • Phone (916) 859-4330 • Fax (916) 859-3717

SACRAMENTO METROPOLITAN FIRE DISTRICT			
FIRE PREVENTION STANDARD			
STANDARD TITLE:	Installation and Maintenance of Private Fire Hydrants		
STANDARD NUMBER:	5	EFFECTIVE DATE:	06/01/07 REVISION DATE: 10/27/16

OBJECTIVE

To ensure that fire hydrants on private property meet the requirements of the Fire District, NFPA 291, *Recommended Practices for Fire Flow Testing and Marking of Hydrants* and NFPA 24, *Standard for the Installation of Private Fire Service Mains and Their Appurtenances*. This Policy will apply to all fire hydrants installed on private property within the jurisdiction of the Sacramento Metropolitan Fire District. This policy does not apply to public fire hydrants installed within a utility easement on private property.

This Policy outlines the procedures to be followed when installing and maintaining private fire hydrants and defines the District's requirements for installations that may be more restrictive or not included in existing codes and standards. All individuals and companies who propose to engage in the installation or alteration of fire hydrants on private property are subject to the requirements of this Policy.

PROCEDURE

1. Private On Site Hydrants

- a. Fire hydrants shall be a Clow 960 or an approved equal.
- b. Fire hydrants shall be mounted on an approved break off check valve.
- c. All fire hydrants shall be supplied by a minimum of eight inch piping. The piping size may be reduced to six inch piping if the distance from the point of connection at the hydrant bury to the main supply piping or public water supply piping is less than 25 feet.
- d. Outlets shall be national standard threads with metal protector caps. One 4½-inch "steamer" outlet and two 2½-inch outlets are required.

**SACRAMENTO METROPOLITAN FIRE DISTRICT
FIRE PREVENTION STANDARD**

STANDARD
TITLE:

Installation and Maintenance of Private Fire Hydrants

STANDARD
NUMBER:

5

EFFECTIVE DATE: 06/01/07

REVISION DATE: 10/27/16

- e. The 2½-inch outlets shall be placed above the 4½-inch “steamer” outlet and be oriented 90 degrees relative to each other.
- f. Nut size of valve/stem and protector caps shall be of pentagonal shape and furnished with a nut of 1⅞-inches measured from point to flat of the pentagon. Hydrant outlet valves shall open in a counter-clockwise direction.
- g. Fire hydrants shall be a minimum of 24 inches in height from base flange to top of hydrant.
- h. Fire hydrants are to be factory painted Rustoleum white or an approved equal.
- i. The fire hydrant base flange shall be a minimum, of 2 inches above the finished grade or planter curb.
- j. Hydrants shall be within 8 feet of the approved fire department access.
- k. Fire hydrants shall not be installed in the bulb of a cul-de-sac.
- l. There shall be a seven-foot vertical clearance above the 36-inch clear radius around the fire hydrant.
- m. Blue reflective hydrant markers shall be installed in accordance with the following:
 - I. On unstriped roadways, blue markers shall be set in the center of the roadway.
 - II. On undivided striped roadways, blue markers shall be set 6" to the hydrant side of the center stripe.
 - III. On divided roadways, the blue marker shall be set 6" to the side of the median or lane striping, which is closest to the hydrant.
 - IV. In locations where hydrants are situated on corners, blue markers shall be installed on both approaches fronting the hydrant.

2. Backflow Prevention

- a. Private fire hydrant supply piping may be provided with backflow prevention devices as required by the local water purveyor.
- b. Flow and pressure loss through the backflow prevention devices shall be taken into consideration when calculating pressure flow and loss for an on-site hydrant system.

3. Looped Systems

- a. Three or more hydrants will require two points of connection to the public or private water supply piping.

SACRAMENTO METROPOLITAN FIRE DISTRICT

FIRE PREVENTION STANDARD

STANDARD
TITLE:

Installation and Maintenance of Private Fire Hydrants

STANDARD
NUMBER:

5

EFFECTIVE DATE: 06/01/07

REVISION DATE: 10/27/16

- b. Two or more hydrants in conjunction with fire sprinkler supply piping will require two points of connection to the public or private water supply piping.
- c. Seven or more fire sprinkler systems will require two points of connection to the public or private water supply piping.
- d. When two or more points of connection to the main water supply are required, they shall be installed as remotely as possible.

4. Shared Utility Agreement

- a. A Shared Utility and Maintenance Agreement shall be recorded at the public recorder's office having jurisdiction and provided to the Fire District for all private fire hydrant systems serving multiple parcels or properties.

5. Installation and Inspections

- a. All runs of non-metallic water pipe shall have a No. 10 gauge solid soft drawn copper locator wire taped on top of the pipe to facilitate locating the pipe at a later date. The wire shall be stubbed up inside each valve box. Continuity test shall be conducted on each splice at all locations.
- b. Non-metallic pipe shall not be used within five feet of a building.
- c. Above grade valves for controlling the water supply for on-site fire hydrant systems shall be supervised.
- d. All piping shall be laid in a six inch bed of sand or natural gravel not over one inch in diameter and have a twelve inch fill of sand or natural gravel not over one inch in diameter. See detail, page 7.
- e. A strand of 3" wide non-detectable blue tape marked "Water" shall be placed 12 inches above all piping.
- f. All sections of ductile iron pipe or ductile iron fittings shall be encased in either 8-mil linear low density (LLD) or 4-mil high-density, cross-laminated (HDCL) polyethylene sheets or tubes in accordance with American Water Works Association Standard C105/A21.5-05, *Polyethylene Encasement for Ductile-Iron Pipe Systems*. Any fasteners shall be made of low-alloy steel.
- g. A fire hydrant flush, using a full pipe diameter discharge, shall be conducted at all hydrants and witnessed by the Fire District. Piping shall be flushed until all foreign objects have been discharged and the water is clear.
- h. Fire District personnel will conduct flow testing to verify the ability of the system to provide the required fire flow.

6. Maintenance and Testing

**SACRAMENTO METROPOLITAN FIRE DISTRICT
FIRE PREVENTION STANDARD**

STANDARD
TITLE:

Installation and Maintenance of Private Fire Hydrants

STANDARD
NUMBER:

5

EFFECTIVE DATE: 06/01/07 REVISION DATE: 10/27/16

a. Annual Maintenance

- I. Ensure hydrant is visible and accessible.
- II. Remove caps and inspect threads, gaskets and cap chains.
- III. Clean and lubricate threads.
- IV. Check condition of pentagon operating nut.
- V. Locate and exercise the underground control valve (key valve, road box or foot valve).
- VI. Fully open and operate each valve on the hydrant.
- VII. Clean and paint hydrant Rustoleum white or equal as necessary.
- VIII. Ensure the blue reflective marker is installed and visible.
- IX. Any deficiencies noted shall be corrected immediately.

b. Five Year Maintenance

- I. Perform annual maintenance as outlined above.
- II. Perform flow testing in accordance with NFPA 291, *Recommended Practices for Fire Flow Testing and Marking of Hydrants*.
- III. Any deficiencies noted shall be corrected immediately.

c. Licensing Requirements

- I. Fire hydrant maintenance and testing shall be performed by one of the following:
 - A. C-16 – Fire Protection Contactor
 - B. C-36 – Plumbing Contractor
 - C. C-34 – Pipeline Contactor
 - D. California State Fire Marshal – License A, Type 1

d. Record Keeping

- I. All maintenance and testing of private fire hydrants shall be recorded and maintained by the property owner. Copies shall be made available to the Fire District upon request.



Gregory Casentini, AC/Fire Marshal

**SACRAMENTO METROPOLITAN FIRE DISTRICT
FIRE PREVENTION STANDARD**

STANDARD
TITLE:

Installation and Maintenance of Private Fire Hydrants

STANDARD
NUMBER: 5

EFFECTIVE DATE: 06/01/07 REVISION DATE: 10/27/16

