



# Sacramento Metropolitan Fire District

## Fire Company Inspection Program

10545 Armstrong Ave., Suite 310 • Mather, CA 95655 • Phone (916) 859-4330 • Fax (916) 859-3717

## APPROVED DOOR HARDWARE

### Self-Releasing Door Hardware

The outside lever is locked and unlocked by a key from the exterior. The inside lever is always unlocked and provides single motion exiting when interior lever is turned.



### Self-Releasing Door Hardware with Code Entry

Door is locked from exterior side at all times (code is required for access). Provides single motion exiting when interior lever is turned.



**Self-Releasing Door Hardware with Interconnected Single Locking Hardware**

Single deadbolt protection with single motion exiting when interior lever is turned. Deadbolt retracts when the interior lever is turned.



**Self-Releasing Door Hardware with Interconnected Multi-Point Locking Hardware**

Multi-point deadbolt protection with single motion exiting when panic bar is depressed. Multi-point locking hardware is also available with lever type handle.



### California Fire Code Locks and latches 1008.1.9.3(2) & 1008.1.9.3(2.2)

In buildings in occupancy Group B and M, the main exterior door or doors are permitted to be equipped with key-operated locking devices from the egress side provided a ready visible sign is posted on or above the egress side of the door stating **THIS DOOR TO REMAIN UNLOCKED DURING BUSINESS HOURS** or **THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED**.




Visible Sign  
Posted on Door

Double Keyed  
Cylinder Deadbolt

### DOUBLE KEYED CYLINDER DEADBOLT

A double cylinder deadbolt requires a key to unlock the door from the outside and inside. This type of deadbolt is approved on the main entrance door in Class B & M occupancies as long as there is a sign on or above the egress side of the door stating **THIS DOOR TO REMAIN UNLOCKED DURING BUSINESS HOURS** or **THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED**.



**PERMITTED**

**SINGLE KEYED CYLINDER DEADBOLT (THUMB-TURN DEADBOLT)**

The most common deadbolt in use is the single keyed deadbolt where a key is required to unlock the door from outside but a simple thumb-turn is used to unlock the door from the inside. Not allowed on any door in Class B & M occupancies unless it is a component of interconnected single locking hardware.



***NOT PERMITTED***  
*Unless it is a component  
of interconnected single  
locking hardware*