Sacramento Metropolitan Fire District
Fire Prevention Bureau

3012 Gold Canal Drive • Rancho Cordova, CA 95670 • Phone (916) 859-4330 • Fax (916) 859-3717

KURT P. HENKE
Fire Chief

SACRAMENTO METROPOLITAN FIRE DISTRICT					
FIRE PREVENTION STANDARD					
STANDARD TITLE:	**Private Subdivision Civil Engineering Notes**				
STANDARD NUMBER:	13	EFFECTIVE DATE:	01/21/04	REVISION DATE:	06/07/12

OBJECTIVE
To provide standard notes for Civil Drawings.

PROCEDURE

The following information must be reproduced as "Sacramento Metropolitan Fire District Notes" for Public Road Subdivisions or Parcel Splits:

1. The minimum required fire flow for residential developments with a total area per structure not exceeding 3,600 square feet is 1,000 gallons per minute at 20 pounds per square inch residual pressure. A Fire District certificate of release is required for structures exceeding 3,600 square feet in total area. For the purposes of fire flow calculation all areas under the buildings roof line, including covered porches, patios, garages, breezeways, etc. are considered.

2. Prior to <u>any</u> combustible construction or storage of combustible materials on-site, the following improvements shall be provided:

   A. Fire hydrants capable of providing the required fire flow shall be installed, tested and approved.
   B. Public roads shall be installed, identified and approved prior to construction or storage of combustible material. Roads may be installed to the "first lift" (up to the last 1" of pavement).

3. Blue reflective hydrant markers shall be placed adjacent to the fire hydrants in accordance with Department of Transportation guidelines.

4. The following information applies to public fire hydrant installations, unless the water purveyor having jurisdiction has more specific requirements:

   A. Fire hydrants shall meet the following minimum requirements:

      1. Fire hydrants shall have a .9 coefficient of discharge or greater and with a maximum head loss of 2 psi at 1000 gpm. Provide specification sheet to plan review section prior to installation.

2. Outlets shall be national standard thread with one 4.5 inch and one 2.5 inch outlets.

B. Fire hydrants shall be located within eight (8) feet of the roadway with the 4-½ inch outlet facing the road. The bottom flange is to be installed a minimum of two (2) inches above the finished grade. The centerline of the 4½-inch discharge outlet is to be a minimum of eighteen (18) inches above the finished grade.

Ray Iverson, AC/Fire Marshal