



Sacramento Metropolitan Fire District

Community Risk Reduction Division

www.metrofire.ca.gov

10545 Armstrong Ave., Suite 310 · Mather, CA 95655 · Phone (916) 859-4330 · Fax (916) 859-3717

SACRAMENTO METROPOLITAN FIRE DISTRICT FIRE PREVENTION STANDARD

STANDARD
TITLE:

Magnetic Resonance Imaging (MRI) Warning Signs

STANDARD
NUMBER:

31

EFFECTIVE DATE: 09/29/22 REVISION DATE: 09/29/22

SCOPE

This standard is for the installation of MRI warning signs for all new and existing MRI machines and is pursuant to Section 509.1.1 of the 2022 California Fire Code and Section 102.8 of the 2022 California Fire Code referencing Section 1224.18.4.3 of the 2022 California Building Code.

SPECIFICATIONS

1. MRI rooms shall be clearly marked with a red light and lighted sign stating, "The Magnet Is On". This light and sign are to be lighted at all times and have a backup energy source to remain illuminated for at least 24 hours in the event of a loss of power.
2. At the Fire Control Room, FACP, and/or fire riser, as determined by the fire code official, a building map shall be provided showing the location of the MRI machine.

EXAMPLES:

