



Sacramento Metropolitan Fire District

Community Risk Reduction Division

www.metrofire.ca.gov

10545 Armstrong Ave., Suite 310 · Mather, CA 95655 · Phone (916) 859-4330 · Fax (916) 859-3717

LIQUID OR GAS-FUELED VEHICLES IN AN ASSEMBLY CHECKLIST

California Fire Code Chapter 3 Section 314

Scope

An operational permit is required to display, operate or demonstrate liquid or gas fueled vehicles or equipment in assembly buildings.

Conditions:

- Fixtures and displays of goods for sale are arranged to maintain free, immediate and unobstructed access to exits. (CFC 314.2)
- Indoor displays of highly combustible goods, including but not limited to fireworks, flammable or combustible liquids, liquefied flammable gases, oxidizing materials, pyroxylin plastics and agricultural goods are located 5 feet or more from entrances to exits and exterior exit doors. (CFC 314.3)
- Batteries in vehicles for display are disconnected. (CFC 314.4)
- Fuel in vehicles for display does not exceed one-quarter tank or 5 gallons (whichever is less). (CFC 314.4)
- Display vehicle fuel tanks and fill openings are closed and sealed to prevent tampering. (CFC 314.4)
- Vehicles, boats or other motorcraft equipment are not fueled or defueled in the building. (CFC 314.4)

Additional Requirements may apply